

SAP E & C ALARM ANNOUNCIATOR TRAINER
(PRODUCT CODE: SAP – 72)



The **Alarm Annunciator Trainer (SAP – 72)** gives idea regarding its use in industry for monitoring, alarm and control process plant parameters.

ALARM ANNOUNCIATOR TRAINER (SAP - 72)

Technical Specification: -

No.	Item Name	Technical Specifications
1	Alarm Annunciator Panel-	M.S. Powder coated, with toggle switches, Test Points, DIN rail Channel. Proper insulated Lugs, Ferruling & Neat wire Dressing & Clamping. Wires & power cables are seated through 1''x1'' PVC cable tray
2	Alarm Annunciator-	No. of windows: 4/6, Supply 230 V AC, Fault input contacts:- NO/NC, Window size:25x 30x 15mm, Cutout size:92x92mm (4 window) and 172x92mm (6 window)
3	Level Switch-	Float Type, 24 V DC, Float Material: SS304, Switching Current: 0.5A
4	Temperature Cabinet (SAP-69) (Optional)-	With Thermostat & Temp. Indicator & Controller, RTD Temperature Range: 0 to 100°C

Range of Experiments-

- ❖ Study of Alarm Annunciator Trainer

Features: -

- ❖ Compact Ergonomic Design.
- ❖ User Friendly, Self Explanatory Systems.
- ❖ Training Manuals mimic Charts for Operation Ease.
- ❖ Fast response time
- ❖ Inbuilt hooter

Services Required-

- ❖ Electric Supply of 1φ 230 VAC, 50Hz

Note-

All descriptive matter and illustrations are intended to give only a general idea of the equipment Detailed specifications may be altered at the company's discretion without any notice.

Manufactured/Marketed By
SAP ENGINEERS & CONSULTANTS

Regd. Off. : Shop No. 26-27,'Srushti', Survey No.82, Near Guru Ganesh Nagar, Eklavya College Road (D.P.Road), Kothrud, Pune - 411 038, India

Telephone : (020) 2538 4737

Mobile : +91 94220 88946, +91 9552475082

Fax : (020) 2538 3544

Email : sales@sapengineers.com

Website : www.sapengineers.com / www.sapengineers.co.in